NFPA 1403

Standard on

Live Fire Training Evolutions

2002 Edition

Copyright © 2002, National Fire Protection Association, All Rights Reserved

This edition of NFPA 1403, *Standard on Live Fire Training Evolutions*, was prepared by the Technical Committee on Fire Service Training and acted on by NFPA at its November Association Technical Meeting held November 10–14, 2001, in Dallas, TX. It was issued by the Standards Council on January 11, 2002, with an effective date of January 31, 2002, and supersedes all previous editions.

This edition of NFPA 1403 was approved as an American National Standard on January 31, 2002.

Origin and Development of NFPA 1403

The ongoing training of fire fighters is the cornerstone of good fire protection in today's world. However, the benefits derived from live fire training can be negated by the injuries and deaths suffered by fire fighters under unsafe and poorly supervised training conditions.

Following a tragic training accident in 1982, which resulted in the deaths of two fire fighters, the Committee on Fire Service Training was urged to address the issue of live fire training evolutions in structures. The committee proceeded to develop NFPA 1403 in order to provide recognized safe practices for conducting such training evolutions.

The first edition, titled *Live Fire Training Evolutions in Structures*, was issued in 1986. It was well received and served as the basis for live fire training evolutions throughout the United States. The document was updated in a 1992 edition. In the 1997 revision, the committee combined NFPA 1403 with NFPA 1406, *Outside Live Fire Training Evolutions*, into a single document.

The committee appointed a task group to review the functionality of the 1997 edition in preparation for the current revision. The task group recommended a general updating of the standard. Edits were made to reflect increased experience with live fire training evolutions. The previous numbering of chapters and paragraphs has changed to reflect requirements in the 2000 edition of the NFPA *Manual of Style*.

In Memoriam, September 11, 2001

We pay tribute to the 343 members of FDNY who gave their lives to save civilian victims on September 11, 2001, at the World Trade Center. They are true American heroes in death, but they were also American heroes in life. We will keep them in our memory and in our hearts. They are the embodiment of courage, bravery, and dedication. May they rest in peace.

Technical Committee on Fire Service Training

William E. Peterson, Chair

Plano Fire Department, TX [E]

Rep. International Fire Marshals Association

Roger W. Bassett, R. W. Bassett & Associates, IL [SE]

John Martin Best, Reedy Creek Improvement District, FL [E]

Donald T. Brady, Symtron Systems Inc., NJ [M]

Gene P. Carlson, VFIS-Glatfelter Insurance Group, PA [I]

Rep. VFIS

Jack L. Cottet, Utica National Insurance Company, NY [I]

Nicholas J. Cricenti, Jr., SFC Engineering Partnership, Inc., NH [SE]

William E. Glover, High Temperature Linings (HTL), VA [U]

David C. Grupp, Kemper Insurance Companies, IL [1]

George Hall, US Air Force-HQ AFCESA, FL [U]

John W. Hoglund, University of Maryland, MD [E]

Larry D. Hughes, North Carolina Department of Insurance, NC [E]

James G. Kellam, Jr., Virginia Beach Fire Department, VA [U]

Rep. International Society of Fire Service Instructors

Kent W. Koelz, Palm Beach Fire/Rescue Department, FL [E]

Cortez Lawrence, Auburn Public Safety Department, AL [E]

Roger M. LeBoeuf, Elliott, LeBoeuf & Associates, VA [SE]

Robert A. Lincoln, Jr., Nassau County Fire Service Academy, NY [U]

John B. Lockwood, Bowie, MD [SE]

Francis T. May, Fire Facilities Inc., IL [M]

John Mike Myers, City of Las Vegas Fire Department, NV [E]

Thomas C. Quillin, Tallahassee Fire Department, FL [U]

Rodney D. Reid, Severns, Reid & Associates, Inc., IL [SE]

Michael T. Richardson, Bullard, KY [M]

Daniel N. Rossos, City of Portland Fire Bureau, OR [E]

James B. Straseske, Illinois Fire Service Institute, IL [U]

Phil Welch, Gaston College, NC [U]

Samuel L. Wilkin, Broward County Fire Rescue, FL [SE]

Alternates

Carl Goodson, Fire Protection Publications, OK [M] (Vot. Alt. to IFSTA Rep.)

Steven J. Williamson, Symtron Systems Inc., NJ [M] (Alt. to D. T. Brady)

Nonvoting

Edward W. Bent, Sacramento, CA

Jerry W. Laughlin, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on all fire service training techniques, operations, and procedures to develop maximum efficiency and proper utilization of available personnel. Such activities can include training guides for fire prevention, fire suppression, and other missions for which the fire service has responsibility.

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

NFPA 1403 Standard on Live Fire Training Evolutions 2002 Edition

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

Information on referenced publications can be found in Chapter 2 and Annex E.

Chapter 1 Administration

1.1 Scope.

This standard shall contain the minimum requirements for training fire suppression personnel engaged in fire-fighting operations under live fire conditions.

1.1.1 The minimum requirements for training shall comprise a basic system that can be adapted to local conditions to serve as a standard mechanism for live fire training.

1.2* Purpose.

The purpose of this standard shall be to provide a process for conducting live fire training evolutions to ensure that they are conducted in safe facilities and that the exposure to health and safety hazards for the fire fighters receiving the training is minimized.

1.3 Application.

Procedures for live fire training evolutions that involve marine structures or vessels and ground cover or wildland fires shall not be covered in this standard.

Chapter 2 Referenced Publications

2.1 General.

The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications.

National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 30, Flammable and Combustible Liquids Code, 2000 edition.

NFPA 58, Liquefied Petroleum Gas Code, 2001 edition.

NFPA 59, Utility LP-Gas Plant Code, 2001 edition.

NFPA 1001, Standard for Fire Fighter Professional Qualifications, 1997 edition.

NFPA 1142, Standard on Water Supplies for Suburban and Rural Fire Fighting, 2001 edition.

NFPA 1971, Standard on Protective Ensemble for Structural Fire Fighting, 2000 edition.

NFPA 1975, Standard on Station/Work Uniforms for Fire and Emergency Services, 1999 edition.

NFPA 1981, Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service, 1997 edition.

NFPA 1982, Standard on Personal Alert Safety Systems (PASS), 1998 edition.

2.3 Other Publications. (Reserved)

Chapter 3 Definitions

3.1 General.

The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not included, common usage of the terms shall apply.

3.2 NFPA Official Definitions.

- 3.2.1* Authority Having Jurisdiction (AHJ). The organization, office, or individual responsible for approving equipment, materials, an installation, or a procedure.
- 3.2.2 Shall. Indicates a mandatory requirement.
- 3.2.3 Should. Indicates a recommendation or that which is advised but not required.
- 3.3 General Definitions.
- 3.3.1 Acquired Prop. A piece of equipment such as an automobile that was not designed for burning but is used for live fire training evolutions.
- 3.3.2 Building.
- 3.3.2.1 Acquired Building. A structure acquired by the authority having jurisdiction from a property owner for the purpose of conducting live fire training evolutions.
- 3.3.2.2* Training Center Burn Building. A structure specifically designed for conducting live fire training evolutions on a repetitive basis.
- 3.3.3 Demonstration. The act of showing a skill.
- 3.3.4 Evolution. A set of prescribed actions that result in an effective fireground activity.
- 3.3.5 Instructor. An individual qualified by the authority having jurisdiction to deliver fire fighter training, who has the training and experience to supervise students during live fire training evolutions.
- 3.3.6 Instructor-in-Charge. An individual qualified as an instructor and designated by the authority having jurisdiction to be in charge of the live fire training evolution.

- 3.3.7 Live Fire. Any unconfined open flame or device that can propagate fire to the building or other combustible materials.
- 3.3.8 Participant. Any student, instructor, safety officer, visitor, or other person who is involved in the live fire training evolution within the operations area.
- 3.3.9 Safety Officer. An individual appointed by the authority having jurisdiction as qualified to maintain a safe working environment at all live fire training evolutions.
- 3.3.10 Student. Any person who is present at the live fire training evolution for the purpose of receiving training.

Chapter 4 Acquired Structures

- 4.1 Student Prerequisites.
- 4.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements for Fire Fighter I in NFPA 1001, Standard for Fire Fighter Professional Qualifications, related to the following subjects:
- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams
- (7) Overhaul

- (8) Water supply
- (9) Ventilation
- (10) Forcible entry
- 4.1.2* Students participating in a live fire training evolution who received the required minimum training specified in 4.1.1 from other than the authority having jurisdiction shall present written evidence of having successfully completed the prescribed training prior to being permitted to participate in any live fire training evolution.
- 4.2 Structures and Facilities.
- 4.2.1* Any building that is considered for a structural fire training exercise shall be prepared for the live fire training evolution.
- 4.2.2* Preparation shall include application for and receipt of required permits and permissions.
- 4.2.3* Ownership of the acquired building shall be determined prior to its acceptance by the authority having jurisdiction.
- **4.2.4** Evidence of clear title shall be required for all structures acquired for live fire training evolutions.
- 4.2.5* Written permission shall be secured from the owner of the structure in order for the fire department to conduct live fire training evolutions within the acquired building.
- 4.2.6 A clear description of the anticipated condition of the acquired building at the completion of the evolution(s) and the method of returning the property to the owner shall be put in writing and shall be acknowledged by the owner of the structure.

- 4.2.7* Proof of insurance cancellation or a signed statement of nonexistence of insurance shall be provided by the owner of the structure prior to acceptance for use of the acquired building by the authority having jurisdiction.
- 4.2.8 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the authority having jurisdiction upon the request of those agencies.
- 4.2.9* All hazardous storage conditions shall be removed from the structure or neutralized in such a manner as to not present a safety problem during use of the structure for live fire training evolutions.
- 4.2.9.1 Closed containers and highly combustible materials shall be removed from the structure.
- 4.2.9.2 Oil tanks and similar closed vessels that cannot be removed shall be vented sufficiently to prevent an explosion or overpressure rupture.
- 4.2.9.3 Any hazardous or combustible atmosphere within the tank or vessel shall be rendered inert.
- 4.2.10 All hazardous structural conditions shall be removed or repaired so as to not present a safety problem during use of the structure for live fire training evolutions.
- 4.2.10.1 Floor openings shall be covered.
- 4.2.10.2 Missing stair treads and rails shall be repaired or replaced.
- 4.2.10.3 Dangerous portions of any chimney shall be removed.
- 4.2.10.4 Holes in walls and ceilings shall be patched.

- 4.2.10.5* Low-density combustible fiberboard and other unconventional combustible interior finishes shall be removed.
- 4.2.10.6* Extraordinary weight above the training area shall be removed.
- 4.2.11 All hazardous environmental conditions shall be removed prior to conducting live fire training evolutions in the structure.
- 4.2.11.1 Debris creating or contributing to unsafe conditions shall be removed.
- 4.2.11.2* Roof ventilation openings that are normally closed but can be opened in the event of an emergency shall be permitted to be utilized.
- 4.2.11.3 Utilities shall be disconnected.
- 4.2.11.4 Any toxic weeds, insect hives, or vermin that could present a potential hazard shall be removed.
- 4.2.11.5 All forms of asbestos deemed hazardous to personnel shall be removed by an approved asbestos removal contractor.
- 4.2.12 Exits from the building shall be identified and evaluated prior to each training burn.
- 4.2.12.1 Participants of the live fire training shall be made aware of exits from the building prior to each training burn.
- 4.2.13 Buildings that cannot be made safe as required by this chapter shall not be utilized for interior live fire training evolutions.
- 4.2.14 Adjacent buildings or property that might become involved shall be protected or removed.

- 4.2.15 Utility services adjacent to the live burn site shall be removed or protected.
- **4.2.16** Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed.
- 4.2.17 Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.
- 4.2.18 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports or heliports, and nursing homes, hospitals, or other similar facilities, shall be identified.
- **4.2.19** The persons in charge of the adjacent properties identified in 4.2.18 shall be informed of the date and time of the evolution.
- 4.2.20* Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions and safeguards shall be taken to eliminate possible hazards to motorists.
- 4.2.21 Fire lines shall be established to keep pedestrian traffic in the vicinity of the training site clear of the operations area of the live burn.
- 4.2.22* Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.
- 4.2.23 The lead instructor shall determine the rate and duration of water flow necessary for each individual live fire training evolution, including the water necessary for control and extinguishment of the training fire, the supply necessary for backup lines to protect personnel, and any water needed to protect exposed property.

- 4.2.23.1 The minimum water supply and delivery for live fire training evolutions shall meet the criteria identified in NFPA 1142, Standard on Water Supplies for Suburban and Rural Fire Fighting.
- 4.2.23.2 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in <u>4.2.23.1</u> shall be available to handle exposure protection or unforeseen situations.
- 4.2.23.3* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.
- 4.2.24 Areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.
- 4.2.24.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.
- 4.2.24.2 If any of the apparatus described in $\underline{4.2.24.1}$ is in service to respond to an emergency, it shall be located in an area to facilitate a prompt response.
- 4.2.24.3 Where required or necessary, parking areas for police vehicles or for the press shall be designated.
- 4.2.24.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated and located where it will facilitate a prompt response in the event of personal injury to participants in the evolution.
- 4.2.24.5 Ingress/egress routes shall be designated, identified, and monitored during the training evolutions to ensure their availability in the event of an emergency.

- 4.2.25 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants, in which all facets of each evolution to be conducted are discussed and assignments made for all crews participating in the training session are given.
- 4.2.25.1 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the briefing.
- 4.2.25.2 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions.
- 4.2.25.3 All features of the training areas and structure shall be indicated on the preburn plan.
- 4.2.25.4 Prior to conducting any live fire training, all participants shall be required to conduct a walk-through of the structure in order to have a knowledge of and familiarity with the layout of the building and to facilitate any necessary evacuation of the building.
- 4.2.26 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.
- 4.2.26.1 Control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.
- 4.2.26.2 Visitors who are allowed within the operations area perimeter to observe operations shall be escorted at all times.
- 4.2.26.3 Visitors allowed within the operations area perimeter shall be equipped with and shall wear complete protective clothing in accordance with $\underline{4.4.17.1}$ through $\underline{4.4.17.7}$.

4.2.27 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

4.3 Fuel Materials.

- 4.3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible.
- 4.3.2 Unidentified materials, such as debris found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be used.
- 4.3.3* Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be used.
- 4.3.4* Fuel materials shall be used only in the amounts necessary to create the desired fire size.
- **4.3.5** The fuel load shall be limited to avoid conditions that could cause an uncontrolled flashover or backdraft.
- **4.3.6** Flammable or combustible liquids, as defined in NFPA 30, Flammable and Combustible Liquids Code, shall not be used in live fire training evolutions in acquired structures.
- 4.3.7* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of fire.
- 4.3.8* The instructor-in-charge shall document fuel loading including all of the following:
- (1) Furnishings

- (2) Wall and floor coverings and ceiling materials
- (3) Type of construction of the structure including type of roof and combustible void spaces
- (4) Dimensions of the room
- 4.3.9* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.
- 4.3.10 An exercise stopped as a result of an assessed hazard according to 4.3.9 shall continue only when actions have been taken to reduce the hazard.
- 4.4 Safety.
- 4.4.1 A safety officer shall be appointed for all live fire training evolutions.
- 4.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.
- **4.4.3** The responsibilities of the safety officer shall include, but shall not be limited to, the following:
- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions
- **4.4.4** The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.
- 4.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

- 4.4.6* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.
- **4.4.6.1** Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).
- **4.4.6.2** Backup lines shall be provided to ensure protection for personnel on training attack lines.
- 4.4.7 The instructor-in-charge then shall assign the following personnel:
- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment
- 4.4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.
- 4.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.
- 4.4.10* A building evacuation plan shall be established, including an evacuation signal to be demonstrated to all participants in an interior live fire training evolution.
- 4.4.11 Emergency medical services shall be available on site to handle injuries.

- **4.4.12** Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.
- 4.4.13 A search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.
- 4.4.14 No person(s) shall play the role of a victim inside the building.
- 4.4.15 Only one fire at a time shall be permitted within an acquired structure.
- **4.4.16** The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.
- **4.4.17** Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).
- **4.4.17.1** All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn properly and are in serviceable condition.
- 4.4.17.2 Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, Standard on Protective Ensemble for Structural Fire Fighting.
- 4.4.17.3 Self-contained breathing apparatus (SCBA) shall have been manufactured to meet the requirements of NFPA 1981, Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service.
- 4.4.17.4* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements

of NFPA 1975, Standard on Station/Work Uniforms for Fire and Emergency Services.

- 4.4.17.5 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, Standard on Personal Alert Safety Systems (PASS).
- 4.4.17.6 All students, instructors, safety personnel, and other personnel shall wear according to manufacturer's instructions all protective clothing and equipment specified in this chapter whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.
- 4.4.17.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever operating under one or more of the following conditions:
- In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (3) In any atmosphere that can become oxygen deficient or contaminated, or both
- (4) Below ground level
- **4.4.18** One person who is not a student shall be designated as the "ignition officer" to control the materials being burned.

- **4.4.18.1** The ignition officer shall wear full protective clothing, including self-contained breathing apparatus (SCBA), as required in <u>4.4.17.1</u> through <u>4.4.17.7</u>, when performing this control function.
- **4.4.18.2** A charged hoseline shall accompany the ignition officer when he or she is igniting any fire.
- 4.4.18.3* The decision to ignite the training fire shall be made by the instructor-in-charge in coordination with the safety officer.
- **4.4.18.4** The fire shall be ignited by the ignition officer in the presence of and under the direct supervision of the safety officer.
- 4.5 Instructors.
- 4.5.1 All instructors shall be qualified to deliver fire fighter training according to the authority having jurisdiction.
- 4.5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.
- 4.5.3 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.
- 4.5.4 The instructor-in-charge shall be responsible for full compliance with this standard.
- 4.5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.
- 4.5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard.

- 4.5.7 Instructors shall monitor and supervise all assigned students during the live fire training evolution.
- 4.5.8 The instructor-in-charge shall provide for rest and rehabilitation of members operating at the scene, including any necessary medical evaluation and treatment, food and fluid replenishment, and relief from climatic conditions. (See Annex D.)

Chapter 5 Gas-Fired Training Center Buildings

- 5.1 Student Prerequisites.
- 5.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements for Fire Fighter I in NFPA 1001, Standard for Fire Fighter Professional Qualifications, related to the following subjects:
- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams
- (7) Overhaul
- (8) Water supply
- (9) Ventilation

(10) Forcible entry

- 5.1.2* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 5.1.1.
- 5.2 Structures and Facilities.
- 5.2.1* Strict safety practices shall be applied to all structures selected for live fire training evolutions.
- 5.2.2* Training center burn buildings shall be inspected visually for damage prior to live fire training evolutions.
- 5.2.2.1 Damage shall be documented.
- 5.2.2.2* The structural integrity of the building shall be evaluated and documented annually by a licensed professional engineer with burn building experience and expertise.
- 5.2.2.3* Part of the burn building evaluation shall include, once every five years, the removal and reinstallation of a representative area of thermal linings (if any) to inspect the hidden conditions behind the linings.
- 5.2.2.4 The engineer shall core solid structural concrete slabs and walls that have been exposed to temperatures in excess of 149°C (300°F) to check for hidden delamination and to test comprehensive strength once every 10 years for conventional (Portland) concrete and every three years for refractory (calcium aluminate) concrete.
- 5.2.2.5 Where the burn building damage is severe enough to affect the safety of the students, training shall not be permitted.

- 5.2.3 All doors, windows and window shutters, roof scuttles and automatic ventilators, mechanical equipment, lighting, manual or automatic sprinklers, and standpipes necessary for the live fire training evolution shall be checked and operated prior to any live fire training evolution to ensure they operate correctly.
- 5.2.4* All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.
- 5.2.5* For burn buildings that contain gas-fueled training systems, the instructors shall run the system prior to exposing students to live flames in order to ensure the correct operation of devices such as the gas valves, flame safeguard units, agent sensors, combustion fans, and ventilation fans.
- 5.2.6 Training center burn buildings shall be left in a safe condition upon completion of live fire training evolutions.
- 5.2.7 Debris hindering the access or egress of fire fighters shall be removed prior to the beginning of the next training exercises.
- 5.2.8 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn and fire lines shall be established for this purpose.
- 5.2.9 Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.
- 5.2.10 The water supply for any individual live fire training evolution shall be assessed based on the extent of the evolutions to be performed.

- 5.2.10.1 Consideration shall be given to the control and extinguishment of the fire and the provision of backup lines to protect personnel.
- 5.2.10.2 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1142, Standard on Water Supplies for Suburban and Rural Fire Fighting.
- 5.2.10.3 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in accordance with $\underline{5.2.10.2}$ shall be available to handle exposure protection or unforeseen situations.
- 5.2.10.4* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

- 5.2.11 Adequate areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.
- 5.2.11.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.
- 5.2.11.2 Consideration shall be given to locating this parking area to facilitate prompt response of apparatus in the event of an emergency.
- 5.2.11.3 Where required or necessary, parking areas for police or press vehicles shall be designated.

- 5.2.11.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated.
- 5.2.11.5 Consideration shall be given to locating the "parking area" to facilitate prompt response in the event of personal injury to participants in the evolution.
- 5.2.11.6 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.
- 5.2.12 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants.
- 5.2.12.1 All facets of each evolution to be conducted shall be discussed in the preburn briefing, and assignments shall be made for all crews participating in the training session.
- 5.2.12.2 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the preburn briefing.
- 5.2.12.3 A preburn plan shall be prepared and utilized during the preburn briefing sessions.
- 5.2.12.4 All features of the training areas and structure shall be indicated on the preburn plan.
- 5.2.13 Prior to conducting any live fire training, all participants shall be required to conduct a walk-through of the structure in order to have a knowledge of and familiarity with the layout of the building and to be able to facilitate any necessary evacuation of the building.
- 5.2.14 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

- 5.2.14.1 Control measures such as ropes, signs, and fire line markings shall be used to indicate the perimeter of the operations area.
- 5.2.14.2 Visitors who are allowed within the operations area perimeter to observe operations shall be escorted at all times.
- 5.2.14.3 Visitors who are allowed within the operations area perimeter shall be equipped with and shall properly wear complete protective clothing in accordance with 5.4.17.1 through 5.4.17.7.
- 5.2.15 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.
- 5.2.16 There shall be ample room provided around all props such that there is space for all attack lines as well as backup lines to operate freely.
- 5.3 Fuel Materials.
- 5.3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible.
- 5.3.2 Unidentified materials, such as debris found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.
- 5.3.3* The use of flammable gas, such as propane and natural gas, shall be permitted only in burn buildings specifically designed for their use.
- **5.3.4** Liquefied versions of the gases specified in 5.3.3 shall not be permitted inside the burn building.
- 5.3.5* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of fire.

- 5.3.6* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.
- 5.3.7 The exercise shall continue only when the appropriate actions have been taken to reduce the hazard.
- 5.4 Safety.
- 5.4.1 A safety officer shall be appointed for all live fire training evolutions.
- 5.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.
- 5.4.3 The responsibilities of the safety officer shall include, but shall not be limited to, the following:
- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions
- 5.4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.
- 5.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.
- 5.4.6 The safety officer shall be knowledgeable in the operation and location of safety features available within the burn building, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.

- 5.4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.
- **5.4.7.1** Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).
- 5.4.7.2 Backup lines shall be provided to ensure protection for personnel on training attack lines.
- 5.4.7.3 The instructor-in-charge shall assign the following personnel:
- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment
- <u>5.4.8*</u> Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.
- 5.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.
- 5.4.10* A building evacuation plan shall be established, including an evacuation signal to be demonstrated to all participants in an interior live fire training evolution.
- 5.4.11 Emergency medical services shall be available on site to handle injuries.

- 5.4.12 Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.
- 5.4.13 A thorough search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.
- 5.4.14 No person(s) shall play the role of a victim inside the building.
- 5.4.15 Fires shall not be located in any designated exit paths.
- 5.4.16 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.
- 5.4.17 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).
- 5.4.17.1 All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn according to manufacturer's instructions and are in serviceable condition.
- 5.4.17.2 Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, Standard on Protective Ensemble for Structural Fire Fighting.
- 5.4.17.3 Self-contained breathing apparatus (SCBA) shall have been manufactured to meet the requirements of NFPA 1981, Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service.
- 5.4.17.4* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements

of NFPA 1975, Standard on Station/Work Uniforms for Fire and Emergency Services.

- 5.4.17.5 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, Standard on Personal Alert Safety Systems (PASS).
- 5.4.17.6 All students, instructors, safety personnel, and other personnel shall wear all protective clothing and equipment specified in this chapter according to manufacturer's instructions whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.
- 5.4.17.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever operating under one or more of the following conditions:
- (1) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (3) In any atmosphere that can become oxygen deficient or contaminated, or both
- (4) Below ground level
- 5.4.18* The decision to ignite a training fire shall be made by the instructor-incharge in coordination with the safety officer.
- 5.4.19 Fires shall not be ignited without an instructor visually confirming that the flame area is clear of personnel.

- 5.4.20 Flammable gas fires shall not be ignited manually.
- 5.5 Instructors.
- 5.5.1 All instructors shall be qualified to deliver fire fighter training according to the authority having jurisdiction.
- 5.5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.
- 5.5.3 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.
- 5.5.4 The instructor-in-charge shall be responsible for full compliance with this standard.
- 5.5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.
- 5.5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard.
- 5.5.7 Instructors shall monitor and supervise all assigned students closely during the live fire training evolution.
- 5.5.8 The instructor-in-charge shall provide for rest and rehabilitation of members operating at the scene, including any necessary medical evaluation and treatment, food and fluid replenishment, and relief from climatic conditions. (See Annex D.)

- 5.5.9 Instructors responsible for conducting live fire training evolutions with a gas-fueled training system shall be trained in the complete operation of the system.
- 5.5.10 The training of instructors shall be performed by an individual authorized by the gas-fueled training system manufacturer or others qualified to perform this type of training.
- 5.5.11 Where concurrent, multiple, live fire training evolutions are being conducted in a specifically designed burn building, the identity of the instructor-in-charge of the evolutions shall be clear to all participants.
- 5.5.12 It shall be this instructor's responsibility to coordinate overall burn building fireground activities to ensure proper levels of safety.

Chapter 6 Non-Gas-Fired Training Center Buildings

- 6.1 Student Prerequisites.
- 6.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements for Fire Fighter I in NFPA 1001, Standard for Fire Fighter Professional Qualifications, related to the following subjects:
- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders

- (6) Fire hose, appliances, and streams
- (7) Overhaul
- (8) Water supply
- (9) Ventilation
- (10) Forcible entry
- 6.1.2* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 6.1.1.
- 6.2 Structures and Facilities.
- 6.2.1* Strict safety practices shall be applied to all structures selected for live fire training evolutions.
- 6.2.2* Training center burn buildings shall be inspected visually for damage prior to live fire training evolutions.
- 6.2.2.1 Damage shall be documented.
- 6.2.2.2* The structural integrity of the building shall be evaluated and documented annually by a licensed professional engineer with burn building experience and expertise.
- 6.2.2.3* Part of the burn building evaluation shall include, once every five years, the removal and reinstallation of a representative area of thermal linings (if any) to inspect the hidden conditions behind the linings.

- 6.2.2.4 The engineer shall core solid structural concrete slabs and walls that have been exposed to temperatures in excess of 149°C (300°F) to check for hidden delaminations and to test compressive strength once every 10 years for conventional (Portland) concrete and every three years for refractory (calcium aluminate) concrete.
- 6.2.2.5 Where the burn building damage is severe enough to affect the safety of the students, training shall not be permitted.
- 6.2.3 All doors, windows and window shutters, roof scuttles and automatic ventilators, mechanical equipment, lighting, manual or automatic sprinklers, and standpipes necessary for the live fire training evolution shall be checked and operated prior to any live fire training evolution to ensure they operate correctly.
- <u>6.2.4*</u> All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.
- 6.2.5 Training center burn buildings shall be left in a safe condition upon completion of live fire training evolutions.
- 6.2.6 Debris hindering the access or egress of fire fighters shall be removed prior to the beginning of the next training exercises.
- 6.2.7 In preparation for live fire training, an inspection of the structure shall be made to determine that the floors, walls, stairs, and other structural components are capable of withstanding the weight of contents, participants, and accumulated water.

- 6.2.8 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports or heliports, and nursing homes, hospitals, or other similar facilities, shall be identified.
- **6.2.9** The persons in charge of the properties described in $\underline{6.2.8}$ shall be informed of the date and time of the evolution.
- 6.2.10* Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions, and safeguards shall be taken to eliminate any possible hazard to motorists.
- 6.2.11 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn by the use of fire lines.
- 6.2.12 Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.
- 6.2.13 The water supply for any individual live fire training evolution shall be assessed based on the extent of the evolutions to be performed.
- 6.2.13.1 Consideration shall be given to the control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.
- 6.2.13.2 The minimum water supply and delivery for live fire training evolutions shall meet the criteria identified in NFPA 1142, Standard on Water Supplies for Suburban and Rural Fire Fighting.
- 6.2.13.3 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in accordance with <u>6.2.13.2</u> shall be available to handle exposure protection or unforeseen situations.

6.2.13.4* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

- 6.2.14 Areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.
- 6.2.14.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.
- 6.2.14.2 Consideration shall be given to locating this area in order to facilitate prompt response of apparatus in the event of an emergency.
- 6.2.14.3 Where required or necessary, parking areas for police vehicles or for the press shall be designated.
- 6.2.14.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated.
- 6.2.14.5 Consideration shall be given to locating this area to facilitate prompt response in the event of a personal injury to participants in the evolution.
- 6.2.14.6 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

- 6.2.15 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants.
- 6.2.15.1 All facets of each evolution to be conducted shall be discussed in the preburn briefing, and assignments shall be made for all crews participating in the training session.
- 6.2.15.2 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the preburn briefing.
- 6.2.15.3 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions.
- 6.2.15.4 All features of the training areas and structure shall be indicated on the preburn plan.
- 6.2.16 Prior to conducting any live fire training, all participants shall be required to conduct a walk-through of the structure in order to have a knowledge of and familiarity with the layout of the building and to facilitate any necessary evacuation of the building.
- 6.2.17 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.
- 6.2.17.1 Control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.
- 6.2.17.2 Visitors who are allowed within the operations area perimeter to observe operations shall be escorted at all times.
- 6.2.17.3 Visitors who are allowed within the operations area perimeter shall be equipped with and shall wear complete protective clothing according to manufacturer's instructions and in accordance with 6.4.17.1 through 6.4.17.7.

- 6.2.18 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.
- 6.3 Fuel Materials.
- 6.3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible.
- 6.3.2 Unidentified materials, such as debris found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.
- 6.3.3 Fuel materials shall be used only in the amounts necessary to create the desired fire size.
- 6.3.4* Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be permitted to be used.
- 6.3.5 The fuel load shall be limited to avoid conditions that could cause an uncontrolled flashover or backdraft.
- 6.3.6* The use of flammable or combustible liquids, as defined in NFPA 30, Flammable and Combustible Liquids Code, shall not be permitted to be used in live fire training evolutions in structures.

Exception: Limited quantities of combustible liquid with a flash point above 38°C (100°F) shall be permitted to be used in a training center burn building that has been specifically engineered to accommodate this fuel.

6.3.7* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of the fire.

- 6.3.8* The instructor-in-charge shall document fuel loading including all of the following:
- (1) Furnishings
- (2) Wall and floor coverings and ceiling materials
- (3) Type of construction of the structure, including type of roof and combustible void spaces
- (4) Dimensions of room
- 6.3.9* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.
- 6.3.10 The exercise shall continue only when the actions have been taken to reduce the hazard.
- 6.4 Safety.
- 6.4.1 A safety officer shall be appointed for all live fire training evolutions.
- 6.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.
- **6.4.3** The responsibilities of the safety officer shall include, but shall not be limited to, the following:
- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions

- **6.4.4** The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.
- 6.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.
- 6.4.6 The safety officer shall be knowledgeable in the operation and location of safety features available within the burn building, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.
- 6.4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.
- 6.4.7.1 Backup lines shall be provided to ensure protection for personnel on training attack lines.
- **6.4.7.2** Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).
- 6.4.7.3 The instructor-in-charge shall assign the following personnel:
- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment
- 6.4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.

- 6.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.
- 6.4.10* A building evacuation plan shall be established, including an evacuation signal to be demonstrated to all participants in an interior live fire training evolution.
- 6.4.11 Emergency medical services shall be available on site to handle injuries.
- 6.4.12 Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.
- 6.4.13 A search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.
- 6.4.14 No person(s) shall play the role of a victim inside the building.
- 6.4.15 Fires shall not be located in any designated exit paths.
- **6.4.16** The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.
- 6.4.17 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).
- 6.4.17.1 All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn according to manufacturer's instruction and are in serviceable condition.

- 6.4.17.2 Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, Standard on Protective Ensemble for Structural Fire Fighting.
- 6.4.17.3 Self-contained breathing apparatus (SCBA) shall have been manufactured to meet the requirements of NFPA 1981, Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service.
- 6.4.17.4* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements of NFPA 1975, Standard on Station/Work Uniforms for Fire and Emergency Services.
- 6.4.17.5 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, Standard on Personal Alert Safety Systems (PASS).
- 6.4.17.6 All students, instructors, safety personnel, and other personnel shall wear all protective clothing and equipment specified in this chapter according to manufacturer's instructions whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.
- 6.4.17.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever operating under one or more of the following conditions:
- (1) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both

- (3) In any atmosphere that can become oxygen deficient or contaminated, or both
- (4) Below ground level
- **6.4.18** One person who is not a student shall be designated as the "ignition officer" to control the materials being burned.
- **6.4.18.1** The ignition officer shall wear full protective clothing, including self-contained breathing apparatus (SCBA), as required in <u>6.4.17.1</u> through 6.4.17.7, when performing this control function.
- **6.4.18.2** A charged hoseline shall accompany the ignition officer when he or she is igniting any fire.
- 6.4.18.3* The decision to ignite the training fire shall be made by the instructor-in-charge in coordination with the safety officer.
- **6.4.18.4** The fire shall be ignited by the ignition officer in the presence of and under the direct supervision of the safety officer.
- 6.5 Instructors.
- **6.5.1** All instructors shall be qualified to deliver fire fighter training according to the authority having jurisdiction.
- 6.5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.
- 6.5.3 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.

- 6.5.4 The instructor-in-charge shall be responsible for full compliance with this standard.
- 6.5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.
- 6.5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard.
- 6.5.7 Instructors shall monitor and supervise all assigned students closely during the live fire training evolution.
- 6.5.8 The instructor-in-charge shall consider the circumstances of each training session and make provisions for the rest and rehabilitation of members operating at the scene, including medical evaluation and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session. (See Annex D.)
- 6.5.9 Where concurrent, multiple, live fire training evolutions are being conducted in a specifically designed burn building, the identity of the instructor-in-charge shall be clear to all participants.
- 6.5.10 It shall be the instructor-in-charge's responsibility to coordinate overall burn building fireground activities to ensure proper levels of safety.

Chapter 7 Exterior Props

- 7.1 Student Prerequisites.
- 7.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements

for Fire Fighter I in NFPA 1001, Standard for Fire Fighter Professional Qualifications, related to the following subjects:

- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams
- (7) Overhaul
- (8) Water supply
- (9) Ventilation
- (10) Forcible entry
- 7.1.2* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 7.1.1.
- 7.2 Structures and Facilities.
- 7.2.1* Strict safety practices shall be applied to all exterior props selected for live fire training evolutions.

- 7.2.2 For outside training, care shall be taken to select areas that limit the hazards to both personal safety and the environment.
- 7.2.3 The training site shall be flat and open without obstructions that can interfere with fire-fighting operations.
- 7.2.4 Where using live training fires outside, the ground cover shall be such that it does not contribute to the fire.
- 7.2.5 The ground cover shall be impervious and of such topography that the runoff from live fire does not enter municipal, private, or public waters or other sensitive areas.
- 7.2.6 Exterior props shall be inspected visually for damage prior to live fire training evolutions.
- 7.2.6.1 Damage to exterior props shall be documented.
- 7.2.6.2 The structural integrity of the props shall be evaluated and documented annually.
- 7.2.7 All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.
- 7.2.8 Exterior props shall be left in a safe condition upon completion of live fire training evolutions.
- 7.2.9 Debris hindering the access of fire fighters shall be removed prior to the beginning of the next training exercise.
- 7.2.10 All required permits to conduct live fire training evolutions shall be obtained.

- 7.2.11 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the authority having jurisdiction upon the request of those agencies.
- 7.2.12 Adjacent buildings or property that might become ignited and involved in fire shall be protected or removed.
- 7.2.13 Utility services adjacent to the live burn site shall be removed or protected.
- 7.2.14 Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed.
- 7.2.15 Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.
- 7.2.16 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports or heliports, and nursing homes, hospitals, or other similar facilities, shall be identified.
- 7.2.17 The persons in charge of the properties described in $\underline{7.2.16}$ shall be informed of the date and time of the evolution.
- 7.2.18* Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions and safeguards shall be taken to eliminate possible hazards to motorists.
- 7.2.19 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn, and fire lines shall be established for this purpose.

- 7.2.20 Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.
- 7.2.21 The water supply for any individual live fire training evolution shall be assessed based on the extent of the evolution to be performed.
- 7.2.21.1 Consideration shall be given to the control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.
- 7.2.21.2 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1142, Standard on Water Supplies for Suburban and Rural Fire Fighting.
- 7.2.21.3 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in accordance with 7.2.21.2 shall be available to handle exposure protection or unforeseen situations.
- 7.2.21.4* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

7.2.22 Areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

- 7.2.22.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.
- 7.2.22.2 Consideration shall be given to locating this parking area in order to facilitate response of apparatus in the event of an emergency.
- 7.2.22.3 Where required or necessary, parking areas for police or press vehicles shall be designated.
- 7.2.22.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated.
- 7.2.22.5 Consideration shall be given to locating this parking area to facilitate prompt response in the event of personal injury to participants in the evolution.
- 7.2.22.6 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.
- 7.2.23 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants.
- 7.2.23.1 All facets of each evolution to be conducted shall be discussed and assignments shall be made for all crews participating in the training session.
- 7.2.23.2 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed in the preburn briefing.
- 7.2.23.3 A preburn plan shall be prepared and utilized during the preburn briefing sessions.
- 7.2.23.4 All features of the training areas and structure shall be indicated on the plan.

- 7.2.24 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the prop or props being used for the evolution.
- 7.2.25 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.
- 7.2.25.1 Control measures such as ropes, signs, and fire line markings shall be used to indicate the perimeter of the operations area.
- 7.2.25.2 Visitors who are allowed within the operations area perimeter shall be escorted at all times.
- 7.2.25.3 Visitors who are allowed within the operations area perimeter shall be equipped with and shall wear complete protective clothing according to manufacturer's instructions and in accordance with 7.4.16 through 7.4.16.7.
- 7.2.26 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.
- 7.2.27 There shall be room provided around all props so that there is space for all attack lines as well as backup lines to operate freely.
- 7.3 Fuel Materials.
- 7.3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible.
- 7.3.2 Unidentified materials, such as debris found in or around the site that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

- 7.3.3* Fuel materials shall be used only in the amounts necessary to create the desired fire size.
- 7.3.4 Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be permitted to be used.
- 7.3.5* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of the fire.
- 7.3.6* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.
- 7.3.7 The exercise shall continue only when actions have been taken to reduce the hazard.
- 7.3.8 Props used for outside live fire training shall be designed specifically for the evolution to be performed.
- 7.3.9* All props that use pressure to move fuel to the fire shall be equipped with remote fuel shutoffs outside of the safety perimeter but within sight of the prop and the entire field of attack for the prop.
- 7.3.10 During the entire time the prop is in use, the remote shutoff shall be continuously attended by safety personnel trained in its operation.
- 7.3.11 Liquefied petroleum gas props shall be equipped with all safety features as described in NFPA 58, Liquefied Petroleum Gas Code, and NFPA 59, Utility LP-Gas Plant Code.
- 7.3.12 Where the evolution involves the failure of a safety feature, the failed part shall be located downstream from the properly functioning safety feature.

- 7.3.13 Measures shall be taken where using flammable or combustible liquids to prevent runoff from contaminating the surrounding area.
- 7.3.14 There shall be oil separators for cleaning the runoff water.
- 7.3.15* Vehicles used as props for live fire training shall have all fluid reservoirs, tanks, shock absorbers, drive shafts, and other gas-filled closed containers removed, vented, or drained prior to any ignition.
- 7.3.16 For flammable metal fires, there shall be a sufficient quantity of the proper extinguishing agent available so that all attack crews have an adequate supply as well as a 150 percent reserve for the use of the backup crews.
- 7.4 Safety.
- 7.4.1 A safety officer shall be appointed for all live fire training evolutions.
- 7.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.
- 7.4.3 The responsibilities of the safety officer shall include, but shall not be limited to, the following:
- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions
- **7.4.4** The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.
- 7.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

- 7.4.6 Backup lines shall be provided to ensure protection for personnel on training attack lines.
- 7.4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.
- 7.4.7.1 Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).
- 7.4.7.2 The instructor-in-charge shall assign the following personnel:
- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment
- (5) One safety person to each manually activated safety station
- 7.4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the area to react to any unplanned or threatening situation or condition.
- 7.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.
- 7.4.10 Emergency medical services shall be available on site to handle injuries.

- 7.4.11 Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.
- 7.4.12 One person who is not a student shall be designated to control the materials being burned and to ignite the training fire in the presence of and under the direct supervision of a safety officer.
- 7.4.12.1 The person designated to control the materials being burned and to ignite the training fire shall wear full protective clothing including self-contained breathing apparatus (SCBA) as required in $\underline{7.4.16.1}$ through $\underline{7.4.16.7}$ of this standard.
- 7.4.12.2 The decision to ignite the training fire shall be made by the instructor-in-charge, in coordination with the safety officer.
- 7.4.13 No person(s) shall play the role of a victim inside the building.
- 7.4.14 Fires shall not be located in any designated exit paths.
- 7.4.15 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.
- 7.4.16 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).
- 7.4.16.1 All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn according to manufacturer's instructions and are in serviceable condition.